

SSO Notification List												
November 2009												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	11/1/2009	2501 W. Franklin St	21223	Grease	Gwynns Falls	0:16	9:09 PM - 9:25 PM	Gray Colored Water	Evidence of Overflow	Jetted M/L with Pressure Truck	Turned over to be CCTV'ed	102292
2	11/3/2009	1800 W. Baltimore St	21223	Rags	Inner Harbor	2:32	3:50 PM - 6:22 PM	Sewer Water	760	Jetted M/L with Pressure Truck	Turned over to be CCTV'ed	102381
3	11/8/2009	2310 Mayfield Ave	21213	Rags & Roots	Herring Run	2:00	5:13 PM - 7:13 PM	Cloudy Water	360	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102542
4	11/12/2009	3100 S. Hanover St	21225	Rags & Grease	Patapsco	2:00	1:26 PM - 3:26 PM	Heavy Gray Water	3000	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102710
5	11/13/2009	Cross Country & Kelly Ave	21209	Pipe Break	Jones Falls	20:00	3:30 PM - 11:30 AM	Sewer Water	2,400	Repaired the Pipe	No Preventative Actions Required	102903
6	11/14/2009	2411 Everton Road	21209	Rags & Grease	Jones Falls	5:00	2:00 PM - 7:00 PM	Heavy Gray Water	900	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102781
7	11/17/2009	4200 Belair Road	21206	Rags & Roots	Herring Run	2:00	10:30 AM - 12:30 PM	Gray Water & Rags	3,600	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102868
8	11/17/2009	4300 Greenspring Ave	21209	Rags & Grease	Jones Falls	0:55	8:30 PM - 9:25 PM	Sewer Water & Grease	825	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	102893
9	11/20/2009	3700 Belair Road	21213	Rags, Roots, & Grease	Herring Run	2:00	11:20 AM - 1:20 PM	Gray Water	360	Relieved M/L Choke with Pressure Truck	Line to be CCTV'ed ASAP	102985
10	11/20/2009	5621 Frankford Ave	21206	Rags & Grease	Herring Run	2:00	12:00 PM - 2:00 PM	Gray Water, Rags & Grease	1,200	Relieved M/L Choke with Pressure Truck	No Preventative Actions Reported	102992
11	11/21/2009	115 Deepdene Rd	21210	Roots	Jones Falls	1:25	8:35 AM - 10:00 AM	Gray Water	425	Relieved M/L Choke with Pressure Truck	Line to be CCTV'ed ASAP	103005
12	11/24/2009	3637 Erdman Avenue	21213	Rags & Grease	Herring Run	1:40	12:20 PM - 2:00 PM	Brown Colored Water	100	Relieved M/L Choke with Pressure Truck	Line to be CCTV'ed ASAP	103115
13	11/25/2009	30 Horseradish Lane	21202	Rags & Grease	Inner Harbor	16:05	4:55 PM - 9:00 PM	Sewer Water, Grease & Paper Debris	965	Jetted M/L with Pressure Truck	Turned over to be CCTV'ed	103176
14	11/26/2009	1100 Gusryan St	21224	Rags & Grease	Inner Harbor	1:24	8:26 PM - 9:50 PM	Sewer Water	1,260	Jetted M/L with Pressure Truck	Turned over to be CCTV'ed	103200
15	11/26/2009	3100 Tioga Parkway	21215	Rags	Gwynns Falls	2:22	10:38 PM - 1:05 AM	Sewer Water	710	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	103186

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
16	11/30/2009	3709 Chesholm Road	21216	Rags & Roots	Gwynns Falls	4:00	8:00 AM - 12:00 PM	Heavy Gray Water	1,200	Relieved M/L Choke with Pressure Truck	Turned over to be CCTV'ed	103268
								TOTAL	18,065			